



China

Attestation of Conformity

No. N8AUK 116477 0011 Rev. 00

Holder of Attestation: **Wuxi Sunket New Energy Technology Co.,Ltd.**

888# Qinghong Road,
Delin Industry Park, E'hu Town
214117 Wuxi, Jiangsu
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Electrical Equipment (Safety) Regulations 2016 relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the regulation and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment.

For details see: www.tuvsud.com/ps-cert

Test report no.: 704062322505-00

Date, 2023-07-24

(David Bo)

Page 1 of 3

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

**UK
CA**

TUV®



China

Attestation of Conformity

No. N8AUK 116477 0011 Rev. 00

Model(s):

SKTxxxM10-144S1, xxx=545~580, in steps of 5,
 SKTxxxM10-144S3, xxx=545~580, in steps of 5,
 SKTxxxM10-132S1, xxx=500~530, in steps of 5,
 SKTxxxM10-132S3, xxx=500~530, in steps of 5,
 SKTxxxM10-120S1, xxx=455~480, in steps of 5,
 SKTxxxM10-120S3, xxx=455~480, in steps of 5,
 SKTxxxM10-108S1, xxx=410~435, in steps of 5,
 SKTxxxM10-108S3, xxx=410~435, in steps of 5,
 SKTxxxM10-60S1, xxx=230~240, in steps of 5,
 SKTxxxM10-48S1, xxx=180~190, in steps of 5,
 SKTxxxM10-36S1, xxx=135~145, in steps of 5,
 SKTxxxM10-24S1, xxx=90~100, in steps of 5,
 SKTxxxM10-12S1, xxx=45~50, in steps of 5,
 SKTxxxM10-72S1, xxx=275~290, in steps of 5,
 SKTxxxM10-64S1, xxx=250~255, in steps of 5,
 SKTxxxM10-56S1, xxx=215~220, in steps of 5,
 SKTxxxM10-40S1, xxx=150~160, in steps of 5,
 SKTxxxM10-32S1, xxx=120~125, in steps of 5,
 SKTxxxM10-16S1, xxx=60
 SKTxxxM10-156D5, xxx=590~625, in steps of 5,
 SKTxxxM10-156D4, xxx=590~625, in steps of 5,
 SKTxxxM10-156D3, xxx=590~625, in steps of 5,
 SKTxxxM10-144D5, xxx=545~580, in steps of 5,
 SKTxxxM10-144D4, xxx=545~580, in steps of 5,
 SKTxxxM10-144D3, xxx=545~580, in steps of 5,
 SKTxxxM10-132D5, xxx=500~530, in steps of 5,
 SKTxxxM10-132D4, xxx=500~530, in steps of 5,
 SKTxxxM10-132D3, xxx=500~530, in steps of 5,
 SKTxxxM10-120D5, xxx=455~480, in steps of 5,
 SKTxxxM10-120D4, xxx=455~480, in steps of 5,
 SKTxxxM10-120D3, xxx=455~480, in steps of 5,
 SKTxxxM10-108D5, xxx=410~435, in steps of 5,
 SKTxxxM10-108D4, xxx=410~435, in steps of 5,
 SKTxxxM10-60D5, xxx=230~240, in steps of 5,
 SKTxxxM10-48D5, xxx=180~190, in steps of 5,
 SKTxxxM10-36D5, xxx=135~145, in steps of 5,
 SKTxxxM10-24D5, xxx=90~100, in steps of 5,
 SKTxxxM10-12D5, xxx=45~50, in steps of 5,
 SKTxxxM10-72D5, xxx=275~290, in steps of 5,
 SKTxxxM10-64D5, xxx=250~255, in steps of 5,
 SKTxxxM10-56D5, xxx=215~220, in steps of 5,
 SKTxxxM10-40D5, xxx=150~160, in steps of 5,
 SKTxxxM10-32D5, xxx=120~125, in steps of 5,
 SKTxxxM10-16D5, xxx=60,
 xxx is standing for rated output power at STC.

Page 2 of 3

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

**UK
CA**

TUV®



China

Attestation of Conformity

No. N8AUK 116477 0011 Rev. 00

Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road Wujin Economic Development Zone Changzhou, Jiangsu, China.

Tested according to:

EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06

Page 3 of 3

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

**UK
CA**

TUV®