

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Name and address of the applicant	Wuxi Sunket New Energy Technology Co.,Ltd. 888# Qinghong Road, Delin Industry Park, E'hu Town 214117 Wuxi, Jiangsu PEOPLE'S REPUBLIC OF CHINA
Name and address of the manufacturer	Wuxi Sunket New Energy Technology Co.,Ltd. 888# Qinghong Road,, Delin Industry Park, E'hu Town, 214117 Wuxi, Jiangsu, PEOPLE'S REPUBLIC OF CHINA
Name and address of the factory	Wuxi Sunket New Energy Technology Co.,Ltd. 888# Qinghong Road,, Delin Industry Park, E'hu Town, 214117 Wuxi, Jiangsu, PEOPLE'S REPUBLIC OF CHINA
Ratings and principal characteristics	Construction: Framed, with Junction box, Cable and Connectors. Safety Class: Class II Maximum System Voltage: 1500 V DC Fire Safety Class: Class C according to UL790 Test Laboratory: Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou,Jiangsu, China
Model/type Ref.	SKTxxxM10-144S1, xxx=545~580, in steps of 5, SKTxxxM10-144S3, xxx=545~580, in steps of 5, SKTxxxM10-132S1, xxx=500~530, in steps of 5, SKTxxxM10-132S3, xxx=500~530, in steps of 5, SKTxxxM10-120S1, xxx=455~480, in steps of 5, SKTxxxM10-120S3, xxx=455~480, in steps of 5, SKTxxxM10-108S1, xxx=410~435, in steps of 5, SKTxxxM10-108S3, xxx=410~435, in steps of 5, SKTxxxM10-60S1, xxx=230~240, in steps of 5, SKTxxxM10-48S1, xxx=180~190, in steps of 5, SKTxxxM10-36S1, xxx=135~145, in steps of 5, SKTxxxM10-24S1, xxx=90~100, in steps of 5, SKTxxM10-12S1, xxx=45~50, in steps of 5, SKTxxxM10-72S1, xxx=275~290, in steps of 5,

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CB 116477 0014 Rev. 00

Date, 2023-08-21



(Zhulin Zhang)

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany



Product Service

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SKTxxxM10-64S1, xxx=250~255, in steps of 5,
SKTxxxM10-56S1, xxx=215~220, in steps of 5,
SKTxxxM10-40S1, xxx=150~160, in steps of 5,
SKTxxxM10-32S1, xxx=120~125, in steps of 5,
SKTxxxM10-16S1, xxx=60
xxx is standing for rated output power at STC

A sample of the product was tested and found to be in conformity with

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016

as shown in the Test Report Ref. No. which forms part of this certificate

083-32322503-000

Trademark / Brand (continued)

Sunket

Trademark / Brand (Image)



Ratings and principal characteristics (continued)



(Zhulin Zhang)